



- 4) All Secondary Spiral Fan Coil Unit Ductwork To Be Internally Lined With 9mm Barafoam Acoustic Lining Including The Plenum Box.

LEGEND:

AP	-	ACCESS PANEL
CE	-	CAP END
BE	-	BLANK END
SE	-	SMALL END
LE	-	LARGE END

FTT	-	FLAT TOP TAPER
FBT	-	FLAT BOTTOM TAPER
SU	-	SET UP
SD	-	SET DOWN

FD - FIRE DAMPER  
SMD - SMOKE DAMPER  
VCD - VOLUME CONTROL DAMPER  
MVCD - MOTORISED VCD  
ID - IRIS DAMPER  
SBD - SINGLE BLADE DAMPER

FTC - FLAT TOP CONNECTION  
FBC - FLAT BOTTOM CONNECTION  
CTS - CUT TO SUIT  
REF - REFERENCE POINT

<u>Rev</u>	<u>Date</u>	<u>Description</u>
------------	-------------	--------------------

# AVEAT HEATING LTD

MECHANICAL, ELECTRICAL,  
PLUMBING & HEATING ENGINEERS

Lambert House, Driberg Way,  
Braintree, Essex, CM7 7NB

TEL:(01376) 341653/325670  
FAX:(01376) 551210

Project:

Olwen House  
8-20 Loman Street  
London  
SE1 0HE

Description:

Proposed New Mechanical  
Ductwork & Fan Coil Unit  
Layout Services.

## Second Floor Level

Drawn:	Scale:	Date:
D.J.Smith	1:50 @ A1	28-11-2018

Drawing Number:	Revision:
C10422-M-DW02	P